

**SGS Canada Inc.** P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO Phone: 705-652-2000 FAX: 705-652-6365

## Kawartha Lake Stewards Association

Attn : Cindy Lee

c/o 264 Bass Lake Rd. Trent Lakes, ON, ON K0M 1A0, Canada

Phone: Fax: 05-August-2021

Date Rec. :03 August 2021LR Report:CA13023-AUG21Reference:North Pigeon Lake<br/>Association

**Copy:** #1

## CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	E. Coli cfu/100mL
1: Analysis Start Date			04-Aug-21
2: Analysis Start Time			09:03
3: Analysis Completed Date			05-Aug-21
4: Analysis Completed Time			13:23
5: PWQO Limits			100
6: Client Limits			50
7: 14 Watergarden Park	02-Aug-21 13:45	10.0	3
8: 13 Mouth of Channel	02-Aug-21 13:50	10.0	9
9: 5A Pigeon Hollow	02-Aug-21 14:24	10.0	34
10: 6 Bell Haven	02-Aug-21 14:28	10.0	21
11: 8 Pigeon Lake Resort	02-Aug-21 14:38	10.0	1

PWQO - Provincial Water Quality Objectives Client Limit - Limit set by client.

I san

Kimberley Didsbury, Project Specialist, Environment, Health & Safety

0002590493

Page 1 of 1 Data reported represents the sample submitted to SGS. Reproduction of this analytical report in full or in part is prohibited without prior written approval. Please refer to SGS General Conditions of Services located at https://www.sgs.ca/en/terms-and-conditions (Printed copies are available upon request.) Test method information available upon request. "Temperature Upon Receipt" is representative of the whole shipment and may not reflect the temperature of individual samples.

SGS Canada Inc. Environment-Health & Safety statement of conformity decision rule does not consider uncertainty when analytical results are compared to a specified standard or